

Drinking Water Quality and Compliance  
**Town of Ituna – Annual Notice to Consumers**

(Note: This short form may be used for communities or waterworks serving a population of less than 5000).

**Introduction**

Saskatchewan Environment (SE) requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the **Town of Ituna's** water quality and sample submission compliance record for the 2010 calendar year. This report was completed on June 23, 2011. Readers should refer to SE's "Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202" for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, more detailed information is available from [www.saskh20.ca](http://www.saskh20.ca).

**Water Quality Standards**

**Bacteriological Quality**

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	52	52	0%

**Water Disinfection –**

**Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples**

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.51 – 2.52 mg/l	0.02 – 1.87 mg/l	55	55	100%

**Water Disinfection - Total Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records**

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Total Chlorine Residual	at least 0.5	0.23 – 2.19	365	1

*A minimum of 0.5 milligrams per litre (mg/L) total chlorine residual is required for water entering and throughout the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of total chlorine residual tests performed, the overall range of total chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.5 mg/L total chlorine residual.*

**Turbidity – From Water Treatment Plant Records**

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	1.0	0.21 – 0.92	0	0.92	365	365

**Chemical – Health Category**

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was required in 2010 and submitted on September 28, 2010. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	Limit MAC(mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit
Aluminum	none set		0.0062	
Arsenic	0.025		0.0010	
Barium	1.0		0.0072	
Boron		5.0	0.3	
Cadmium	0.005		<0.0003	
Chromium	0.05		0.0010	
Copper	1.0		0.23	
Fluoride (avg*)	1.5			
Lead	0.01		0.0002	
Nitrate (avg.*)	45.0			
Selenium	0.01		0.0001	
Uranium	0.02		<0.0001	
Zinc	5.0		0.044	

\*Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.

### **General Chemical**

Parameter	Aesthetic Objectives* (mg/L)	Sample Results (average)	# Samples Required	# Samples Submitted
Alkalinity	500		0	0
Bicarbonate	No Objective			
Calcium	No Objective			
Carbonate	No Objective			
Chloride	250			
Conductivity	No Objective			
Hardness	800			
Magnesium	200			
PH	No Objective			
Sodium	300			
Sulphate	500			
Total dissolved Solids	1500			

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required in 2009 and submitted on August 25, 2009.

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

### **More information on water quality and sample submission performance may be obtained from:**

Town of Ituna  
Box 580  
Ituna, SK  
S0A 1N0